

# ADVERTISED PLAN


FOR DETAILS OF REMAINING SWITCHYARD EAST OF ACCESS ROAD  
BAYS A TO F REFER TO DRG No.T2/119/14/1

### NOTES:

1. HYDRANT (ITEM 16) RELOCATED.
2. POSITION OF AC BOARD TO BE LOCATED UNDERNEATH RACK STRUCTURE.
3. INSULATED PANEL TO BE USED TO CONNECT INTERNAL FENCE TO BOUNDARY FENCE & EITHER SIDE OF OUTDOOR ITC.
4. DETAILS OF BACK TO BACK ITC PANELS TO BE ADVISED BY SPAusnet.

### LEGEND:

- AERIAL CONDUCTOR
- TUBULAR BUSBAR
- FENCE
- TDV FENCE INDICATING PROPERTY BOUNDARY
- INSULATED FENCE PANEL
- DISCONNECT SWITCH OPERATING POSITION
- EARTH SWITCH OPERATING POSITION
- OUTDOOR DISTRIBUTION BOARD
- LIGHTING SWITCHBOARD
- CABLE PIT
- CABLE PIT UNDER ROAD
- EXPANSION BUSBAR JOINT
- FIXED BUSBAR FITTING
- 1000x1000mm PIT
- LIGHT MAST
- LIGHTING POSITION
- OUTDOOR SIDE BY SIDE ISOLATION/INTERFACE CUBICLE
- SECURITY CAMERA AND POLE



This copied document to be made available for the sole purpose of enabling its consideration and review as part of a planning process under the Planning and Environment Act 1987. The document must not be used for any purpose which may breach any copyright

REFERENCE DRAWINGS	DATE	REV	DESCRIPTION	BY	CONTRACTOR	ISSUED
220kV SWITCHYARD SHEET 1	T2/119/14/1					
B3 TRANSFORMER PLAN	T2/119/399					
220kV SWITCHYARD - EARTHING	T2/119/77					
220kV SWITCHYARD - MATERIAL SCHEDULE SHEET 1, 2 & 3	T2/119/19/1 .2 & 3					
220kV SWITCHYARD - SECTIONS A, B, C, D, E AND F	T2/119/15, 16					
SITE PLAN	T2/119/84					
DRAWING TITLE	DRAWING No.	DATE	REV	DESCRIPTION	BY	CONTRACTOR
		2.4.20	4.0	REVISED FENCING AND GATE ACCESS. ADDED SECURITY CAMERA AND TILT POLE. REVISED TO SITE INFO.	BJH	AUSNET SERVICES
		19.04.11	C	ADDED CB SWITCHING STATION (Z926)	J.M	W/Parsons
		20.12.10	B	EARTH SWITCH MODIFIED (Z926)	J.M	W/Parsons
		08.09.10	A	ORIGINAL ISSUE (Z926)	S.A./J.M	W/Parsons

		<b>CRANBOURNE TERMINAL STATION</b> <b>220kV SWITCHYARD</b> <b>LAYOUT</b> <b>SHEET 2</b>	
Spec No.	Order No.	Legacy No.	
Contractors No.	Contractors No.	Contractors No.	
Manuf No.	Manuf No.	Manuf No.	
			T2/119/14/2
			CBTS-0145923-002
			4.0

[UNCONTROLLED WHEN PRINTED]

This drawing and any information or descriptive matter set out hereon are the confidential and copyright property of AusNet Services and must not be disclosed, loaned, copied or used for manufacturing, tendering or for any other purpose without written permission © 2019

[B1]