Construction Standard

The building will be designed and constructed to a minimum Bushfire Attack level of BAL 29. Defendable Space

Defendable space to the property boundary must be provided where vegetation (and other

- flammable materials) will be modified and managed in accordance with the following requirements: Grass must be short cropped and maintained during the declared fire danger period.
- danger period. All leaves and vegetation debris must be removed at regular intervals during the declared fire
- Within 10 metres of a building, flammable objects must not be located close to the vulnerable
- Plants greater than 10 centimetres in height must not be placed within 3m of a window or glass parts of the building.
- Shrubs must not be located under the canopy of trees feature of the building.
- least 5 metres. Individual and clumps of shrubs must not exceed 5 sq. metres in area and must be separated by at
- Trees must not overhang or touch any elements of the building
- The canopy of trees must be separated by at least 5 metres
- There must be a clearance of at least 2 metres between the lowest tree branches and ground level

Unless otherwise agreed in writing by the relevant fire authority, the 5,000 litre water supply must: Be stored in an above ground water tank constructed of concrete or metal

- Have all fixed above-ground water pipes and fittings required for firefighting purposes made of corrosive resistant metal.
- Include a separate outlet for occupant use

ADVERTISED PLAN

This copied document to be made available for the sole purpose of enabling its consideration and review as part of a planning process under the Planning and Environment Act 1987. The document must not be used for any purpose which may breach any copyright



Euildings Defendable Space Property Boundary Saliding (Approx) ☐ Defendable space Defendable space Saliding (Approx) ☐ Defendable Space

Water Supply Property Boundary 5,000 litre static water supply

_egend