


ADVERTISED PLAN



LOCATION PLAN (N.T.S)

NOTES

1. ACTUAL DIMENSIONS AND CLEARANCES MAY VARY SUBJECT TO SITE CONDITIONS.
2. DIMENSIONS OF ELECTRICAL EQUIPMENT ARE INDICATIVE ONLY. ACTUAL DIMENSIONS TO BE CONFIRMED.
3. LOCATION OF POWERCOR 22kV OVERHEAD LINE AND SYSTEM CONNECTION POINT TO BE CONFIRMED.
4. EXISTING/NEW POWERCOR 22kV POLE IS FOR ILLUSTRATION ONLY. ACTUAL POSITION IS SUBJECT TO THE ACTUAL MEASUREMENT ON SITE. PROJECT CONNECTION TO POWERCOR 22kV NETWORK ASSUMED TO BE VIA A NEW POLE LOCATED ON SITE. FINAL CONNECTION ARRANGEMENT TO BE ADVISED BY POWERCOR.
5. SITE STORAGE AND AMENITY FACILITIES TO BE ON SITE ONLY DURING CONSTRUCTION PHASE. NO PERMANENT BUILDINGS TO BE KEPT ON SITE AFTER CONSTRUCTION COMPLETED.
6. THE FOLLOWING SITE FACILITIES WILL BE PROVIDED: 2xSITE OFFICE (6m x 3m), 1xLUNCH ROOM (6m x 3m), 2xTOOLS CONTAINER (6m x 3m), 1xTOLTE (2.4m x 2.4m), 1xWATER TANK (25,000L).
7. INTERNAL ROAD INDICATIVE ONLY AND WILL ONLY BE BUILT IF REQUIRED DURING CONSTRUCTION.
8. THE TREE ICON RANGE INDICATES THE TREE PROTECTION ZONE IN ACCORDANCE WITH AS 4971-2009.

LEGEND

- PROPOSED PV ARRAY
- SECURITY FENCE
- PROPERTY BOUNDARY

SYSTEM SPECIFICATIONS

DC	6.42	MW	TOTAL MODULES	12844
MODULE CAPACITY	500	W	MODULES PER STRING	26
NUMBER OF INVERTERS	1	-	NUMBER OF STRINGS	494
INVERTER MODEL	SMA 4600	-	MODULE MODEL	RSM150-8

FOR INFORMATION




This copied document to be made available for the sole purpose of enabling its consideration and review as part of a planning process under the Planning and Environment Act 1987. The document must not be used for any purpose which may breach any copyright.

No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
D	27/06/22	ACE	ACE	ACE	ACE	VIC-48	UPDATE T.P.Z.		
C	14/06/22	ACE	ACE	ACE	ACE	VIC-48	CHANGE THE CONNECTION POINT		
B	03/11/21	ACE	ACE	ACE	ACE	VIC-48	DRAFT LAYOUT FOR INFORMATION		
A	11/08/20	ACE	ACE	ACE	ACE	VIC-48	DRAFT LAYOUT		
REVISION							REFERENCE DRAWINGS		



6 Meridian Road, Yelta, VIC, 3505
4.95 MW PV EXPORT SYSTEM
SITE PLAN

DATE: 27/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: 1:2000
PROJ No: VIC-48	DRG No:				REV D



NOTES **LOCATION PLAN (N.T.S)**

1. ACTUAL DIMENSIONS AND CLEARANCES MAY VARY SUBJECT TO SITE CONDITIONS.
2. DIMENSIONS OF ELECTRICAL EQUIPMENT ARE INDICATIVE ONLY. ACTUAL DIMENSIONS TO BE CONFIRMED.
3. LOCATION OF POWERCOR 22kV OVERHEAD LINE AND SYSTEM CONNECTION POINT TO BE CONFIRMED.
4. EXISTING/NEW POWERCOR 22kV POLE IS FOR ILLUSTRATION ONLY. ACTUAL POSITION IS SUBJECT TO THE ACTUAL MEASUREMENT ON SITE. PROJECT CONNECTION TO POWERCOR 22kV NETWORK ASSUMED TO BE VIA A NEW POLE LOCATED ON SITE. FINAL CONNECTION ARRANGEMENT TO BE ADVISED BY POWERCOR.
5. SITE STORAGE AND AMENITY FACILITIES TO BE ON SITE ONLY DURING CONSTRUCTION PHASE. NO PERMANENT BUILDINGS TO BE KEPT ON SITE AFTER CONSTRUCTION COMPLETED.
6. THE FOLLOWING SITE FACILITIES WILL BE PROVIDED: 2xSITE OFFICE (6m x 3m), 1xLUNCH ROOM(6m x 3m), 2xTOOLS CONTAINER(6m x 3m), 1xTOLTE(2.4m x 2.4m), 1xWATER TANK(25,000L).
7. INTERNAL ROAD INDICATIVE ONLY AND WILL ONLY BE BUILT IF REQUIRED DURING CONSTRUCTION.
8. THE TREE ICON RANGE INDICATES THE TREE PROTECTION ZONE IN ACCORDANCE WITH AS 4971-2009.

LEGEND

- PROPOSED PV ARRAY
- SECURITY FENCE
- PROPERTY BOUNDARY

SYSTEM SPECIFICATIONS				
DC	6.42	MW	TOTAL MODULES	12844
MODULE CAPACITY	500	W	MODULES PER STRING	26
NUMBER OF INVERTERS	1	-	NUMBER OF STRINGS	494
INVERTER MODEL	SMA 4600	-	MODULE MODEL	RSM150-8



FOR INFORMATION

No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
D	27/06/22	ACE	ACE	ACE	ACE	VIC-48	UPDATE T.P.Z.		
C	14/06/22	ACE	ACE	ACE	ACE	VIC-48	CHANGE THE CONNECTION POINT		
B	03/11/21	ACE	ACE	ACE	ACE	VIC-48	DRAFT LAYOUT FOR INFORMATION		
A	11/08/20	ACE	ACE	ACE	ACE	VIC-48	DRAFT LAYOUT		
REVISION							REFERENCE DRAWINGS		



6 Meridian Road, Yelta, VIC, 3505
4.95 MW PV EXPORT SYSTEM
SITE PLAN

DATE: 27/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: 1:2000
PROJ No: VIC-48	DRG No:				REV D



LOCATION PLAN (N.T.S) NOTE 6

NOTES

1. ACTUAL DIMENSIONS AND CLEARANCES MAY VARY SUBJECT TO SITE CONDITIONS.
2. DIMENSIONS OF ELECTRICAL EQUIPMENT ARE INDICATIVE ONLY. ACTUAL DIMENSIONS TO BE CONFIRMED.
3. LOCATION OF POWERCOR 22kV OVERHEAD LINE AND SYSTEM CONNECTION POINT TO BE CONFIRMED.
4. EXISTING/NEW POWERCOR 22kV POLE IS FOR ILLUSTRATION ONLY. ACTUAL POSITION IS SUBJECT TO THE ACTUAL MEASUREMENT ON SITE. PROJECT CONNECTION TO POWERCOR 22kV NETWORK IS ASSUMED TO BE VIA 3C 700mm² CU XPLE UNDERGROUND CABLE.
5. SITE STORAGE AND AMENITY FACILITIES TO BE ON SITE ONLY DURING CONSTRUCTION PHASE. ONE 25,000 L WATER TANK IS INSTALLED FOR FIREFIGHTING PURPOSE. NO PERMANENT BUILDINGS TO BE KEPT ON SITE AFTER CONSTRUCTION COMPLETED.
6. DUE TO THE LIMITATION OF ONLINE MAP INFORMATION, THE SITE BOUNDARY MAY NOT BE ALIGNED WITH THE LOT BOUNDARY ON THE MAP. THE LOCATION PLAN ONLY INDICATES THE NEARBY LOCALITY INFORMATION.

LOCALITY	
NO.	PROPERTY
1,8	PUBLIC LAND OR PARK
12	YELTA RAIL STATION & RAIL WAY
2-7,9-11,13-20	PRIVATE LAND
D1-D18	DWELLINGS NEAR THE SITE

LEGEND

- PROPOSED PV ARRAY
- SECURITY FENCE
- PROPERTY BOUNDARY
- 1 km RADIUS OF THE SOLAR FARM

FOR INFORMATION

No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
B	10/06/22	ACE	ACE	ACE	ACE	VIC 48	ADD DWELLINGS		
A	08/06/22	ACE	ACE	ACE	ACE	VIC-48	DRAFT LAYOUT		SITE PLAN REV B
REVISION							REFERENCE DRAWINGS		




6 Meridian Road, Yelta, VIC, 3505
 4.95 MW PV EXPORT SYSTEM
 SITE LOCALITY LAYOUT

DATE: 10/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: NTS
PROJ No: VIC-48	DRG No:				REV B


1 2 3 4 5 6 7 8 9 10 11 12

A
B
C
D
E
F
G
H


A
B
C
D
E
F
G
H




SITE FACILITIES LAYOUT
1:100



Right View




Front View




Top View

SITE OFFICE DETAILS
1:50




Top View




Front View


WATER TANK DETAILS
1:50



Front View




Left View




Top View


SITE TOILET DETAILS
1:50



Front View



Left View



Top View

TOOL CONTAINERS DETAILS
1:50

No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
A	07/06/22	ACE	ACE	ACE	ACE		FOR INFORMATION		
REVISION REFERENCE DRAWINGS									



GREEN GOLD ENERGY
PV EXPORT SYSTEM
PROPOSED SITE FACILITIES LAYOUT

DATE: 07/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: NTS
PROJ No	DRG No				REV A

SEAL

THESE PLANS HAVE BEEN PREPARED BY OTHERS AND SEALED BY STRUCTUROLOGY LLC FOR CONFORMANCE OF STRUCTURAL ITEMS ONLY.

GREEN AND GOLD ENERGY

PROJECT NUMBER: -----

SITE ID: -----

SHEET TITLE:

76 MODULE TRACKER DETAILS

NO.	REVISION	DATE	INIT.
A	GEN MECH. SET	07/09/2021	TJ
B			
C			
D			
E			
F			
G			
H			
I			


SITE DETAILS

LATITUDE	-
LONGITUDE	-
SNOW LOAD	-- PSF
WIND LOAD	-- MPH ASCE 7-10
STOW STRAT.	-- STOW - --MPH
NEXTRACKER	NXH 2.4.1.18
76 TRACKER	7-8-8-8-7-M-7-8-8-8-7
38 TRACKER	-M-7-8-8-8-7
DATE	07/09/2021
DRAWN BY	TJ
CHECKED BY	-

SHEET NO.:

M-101

IF BAR IS NOT TWENTY MILLIMETERS, PRINT IS NOT TO SCALE.




1 PIER SPACING
SCALE: N.T.S.

6 SELF-POWERED CONTROLLER, TYP.




3 TRACKER ELEVATION, EXT
SCALE: N.T.S.

4 TRACKER ELEVATION, EDGE
SCALE: N.T.S.


5 TRACKER ELEVATION, INT
SCALE: N.T.S.




9 DAMPER, TYP.
SCALE: N.T.S.




11 SPT WEATHER STATION, ULTRASONIC WIND SENSOR
SCALE: N.T.S.




12 SPT WEATHER STATION, ULTRASONIC SNOW SENSOR
SCALE: N.T.S.



6 SELF POWERED CONTROLLER
SCALE: N.T.S.




7 HEAVY BHA, TYP.
SCALE: N.T.S.




8 LIGHT BHA, TYP.
SCALE: N.T.S.

ACTUAL OPTIMAL DIMENSIONS MAY DEPEND ON SPECIFIC CONDITIONS OF THE SITE.


NOT FOR CONSTRUCTION




1 PIER SPACING
SCALE: N.T.S.




3 TRACKER ELEVATION, EXT
SCALE: N.T.S.




4 TRACKER ELEVATION, EDGE
SCALE: N.T.S.




5 TRACKER ELEVATION, INT
SCALE: N.T.S.




6 SELF POWERED CONTROLLER
SCALE: N.T.S.




9 DAMPER, TYP.
SCALE: N.T.S.




7 HEAVY BHA, TYP.
SCALE: N.T.S.




8 LIGHT BHA, TYP.
SCALE: N.T.S.



11 SPT WEATHER STATION, ULTRASONIC WIND SENSOR
SCALE: N.T.S.




12 SPT WEATHER STATION, ULTRASONIC SNOW SENSOR
SCALE: N.T.S.



SEE DETAIL 1 DIMENSIONS FOR BAY AND TRACKER LENGTHS ARE TAKEN FROM CENTER OF BEAMS. SEE FOUNDATION DRAWING FOR IDENTIFICATION OF PIER TYPES.

2 CENTER OF WEB
SCALE: N.T.S.



10 DOUBLE DAMPER
SCALE: N.T.S.

SEAL

THESE PLANS HAVE BEEN PREPARED BY OTHERS AND SEALED BY STRUCTUROLOGY LLC FOR CONFORMANCE OF STRUCTURAL ITEMS ONLY.

GREEN AND GOLD ENERGY

PROJECT NUMBER:

SITE ID:

SHEET TITLE:

38 MODULE TRACKER DETAILS

NO.	REVISION	DATE	INIT.
A	GEN MECH. SET	07/09/2021	TJ
B			
C			
D			
E			
F			
G			
H			
I			

SITE DETAILS

LATITUDE	-
LONGITUDE	-
SNOW LOAD	-- PSF
WIND LOAD	-- MPH ASCE 7-10
STOW STRAT.	-- STOW -- MPH
NEXTRACKER	NXH 2.4.1.18
76 TRACKER	7-8-8-7-M-7-8-8-7
38 TRACKER	-M-7-8-8-7
DATE	07/09/2021
DRAWN BY	TJ
CHECKED BY	-


SHEET NO.:

M-102


ACTUAL OPTIMAL DIMENSIONS MAY DEPEND ON SPECIFIC CONDITIONS OF THE SITE.

NOT FOR CONSTRUCTION

IF BAR IS NOT TWENTY MILLIMETERS, PRINT IS NOT TO SCALE.




1A TYPICAL MIN. PIER HEIGHT
SCALE: N.T.S.



1B TYPICAL MAX. PIER HEIGHT
SCALE: N.T.S.

2.4 TOLERANCE TABLE		
MEASUREMENT TYPE	0-6.1% (STANDARD SLOPE)	>6.1-15% (HIGH SLOPE)
TOP OF PIER E-W POSITION	+/- 1" (25.4 mm)	
TOP OF PIER N-S POSITION	+/- 1 3/8" (45.5 mm)	+/- 1 3/8" (34.9 mm)
PIER VERTICAL	+/- 1 1/8" (17.5 mm)	+/- 1/2" (12.7 mm)
PIER TWIST	+/- 5°	
0 - 3% TRACKER SLOPE	PIER PLUMB E-W +/- 1.5°	-
	PIER PLUMB N-S +/- 3°	-
>3 - 15% TRACKER SLOPE	PIER PLUMB E-W +/- 1.5°	-
	PIER PLUMB N-S +/- 1.5°	-



2 PIER HEIGHT TOLERANCES
SCALE: N.T.S.


- NOTES:
- 1) TO ALIGN THE PIER TOPS IN A PLANE, SET THE END PIERS OF THE TRACKER ROW FIRST, THEN USE A LASER OR STRING TO SET THE HEIGHTS OF ALL PIERS IN BETWEEN.
 - 2) IF THE EXISTING GRADE IS NOT LEVEL, TO ENSURE PIER HEIGHTS FALL WITHIN THE TOLERANCE AS SHOWN IN "TOLERANCE TABLE", MAKE MAXIMUM PIER HEIGHT IN EACH ROW AT LOWEST ELEVATION POINT OF GRADE FOR THAT ROW.
 - 3) MOTOR PIER MUST BE IN THE PLANE OF THE ARRAY PIERS.

2 PIER HEIGHT TOLERANCES


TOP OF ALL ARRAY PIERS MUST LIE IN THE SAME HORIZONTAL PLANE AS ADJACENT PIER TOPS TO WITHIN THE TOLERANCE AS SHOWN IN "TOLERANCE TABLE". SEE DETAIL 2.

NOMINAL PLANE OF PIER TOPS


3 TRACKER PLANAR TOLERANCES
SCALE: N.T.S.



4 PLANE PARALLEL W/ AVERAGE GROUND SLOPE
SCALE: N.T.S.



5 BHA BRACKET ANGLE
SCALE: N.T.S.



6 MOTOR BRACKET ANGLE
SCALE: N.T.S.

NOTE: WHEN CREATING A PLANE FOR THE TRACKER, THE PLANE SHOULD MATCH THE AVERAGE GROUND SLOPE ACROSS THE TRACKER. THE MOTOR AND BHA BRACKETS SHOULD BE SET TO THIS SLOPE AS SHOWN IN DETAILS 2 AND 3 IN ORDER TO MOUNT THE SLEW GEAR AND BHAS PROPERLY.

ACTUAL OPTIMAL DIMENSIONS MAY DEPEND ON SPECIFIC CONDITIONS OF THE SITE.

NOT FOR CONSTRUCTION

NEXTracker
A Flex Company

NEXTracker Inc.
6200 Paseo Padre Parkway
Fremont, CA 94555

THE DOCUMENT CONTAINS PROPRIETARY INFORMATION. REPRODUCTION OR TRANSMISSION WITHOUT WRITTEN AUTHORIZATION FROM NEXTRACKER, INC. IS STRICTLY FORBIDDEN.

SEAL

THESE PLANS HAVE BEEN PREPARED BY OTHERS AND SEALED BY STRUCTUROLOGY LLC FOR CONFORMANCE OF STRUCTURAL ITEMS ONLY.

GREEN AND GOLD ENERGY

PROJECT NUMBER:

SITE ID:

SHEET TITLE:

PIER TOLERANCES

NO.	REVISION	DATE	INIT.
A	GEN MECH. SET	07/09/2021	TJ
B			
C			
D			
E			
F			
G			
H			
I			

SITE DETAILS

LATITUDE	-
LONGITUDE	-
SNOW LOAD	-- PSF
WIND LOAD	-- MPH ASCE 7-10
STOW STRAT.	-- STOW -- MPH
NEXTRACKER	NXH 2.4.1.18
76 TRACKER	7-8-8-7-M-7-8-8-7
38 TRACKER	-M-7-8-8-7
DATE	07/09/2021
DRAWN BY	TJ
CHECKED BY	-


SHEET NO.:

M-201


IF BAR IS NOT TWENTY MILLIMETERS, PRINT IS NOT TO SCALE.

1 2 3 4 5 6 7 8 9 10 11 12


A
B
C
D
E
F
G
H




Right View



Front View



Left View



Top View




No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
A	07/06/22	ACE	ACE	ACE	ACE		FOR INFORMATION		
REVISION									
REFERENCE DRAWINGS									




GREEN GOLD ENERGY
PV EXPORT SYSTEM
SMA MVPS 2660-S2 INVERTER


DATE: 07/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: NTS
PROJ No	DRG No				REV A



Top View



Front View



Back View



A

B

C

D

E

F

G

H

A

B

C


D

E


F

G


H




Right View





Left View



Bottom View



SECTION A-A




No	DATE	DRN	CHK	ENG	Q.A.	PROJECT	DESCRIPTION	NUMBER	TITLE
A	07/06/22	ACE	ACE	ACE	ACE		FOR INFORMATION		
REVISION									
REFERENCE DRAWINGS									




GREEN GOLD ENERGY
PV EXPORT SYSTEM
ABB HV SWITCHBOARD


DATE: 07/06/22	DRN: ACE	CHK: ACE	ENG: ACE	Q.A: ACE	SCALE: NTS
PROJ No	DRG No				REV A




CHAIN LINK FABRIC FENCE AND OPENING DOUBLE GATE - 6000 GATE
SCALE 1:20



TYPICAL CHAIN MESH FENCE PANEL - 3300 DISTANCE
SCALE 1:20



CORNER POST FOOTING PLAN (>90)
SCALE 1:20



CORNER POST FOOTING PLAN (<90)
SCALE 1:20

NOTES

- CHAIN LINK FABRIC TO BE CLASS 2 TYPE 1-R-L/B-T RAILED LESS 3 BARBED TOP SECURITY FENCING AS PER AS1725.1.
- CHAIN LINK FABRIC TO BE ZINC/ALUM-ALLOY 2.50mm (LIGHT DUTY) WIRE WITH 50MM NOMINAL PITCH MESH (OR SIMILAR APPROVED)
- SUPPORT CABLE TO BE 4mm SINGLE STRAND WITH ZINC/ALUM-ALLOY COATING (OR SIMILAR APPROVED)
- LACING WIRE TO BE 2mm WITH ZINC/ALUM-ALLOY COATING (OR SIMILAR APPROVED)
- CONCRETE FOOTING SHALL BE IN ACCORDANCE WITH AS3600, AND NOT LESS THAN THE MINIMUM SIZE SPECIFIED IN THIS DRAWING.
- CONCRETE SHALL HAVE A CHARACTERISTIC COMPRESSIVE STRENGTH AT 28 DAYS OF 25MPA
- GATES SHALL BE DESIGNED FOR BOTH INWARDS AND OUTWARDS OPENING
- GATE DETAILS PROVIDED ON THIS DRAWING ARE TO BE USED AS ALTERNATIVE TO THE DRAWINGS PLC FENCING PROVIDE.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH AS1725.1 AND PLC FENCING DRAWING AND DESIGN
- ALL DIMENSIONS MENTIONED IN THIS DRAWING ARE IN mm, , OR OTHERWISE SPECIFIED

POST				FOOTING SIZE	
TYPE	DN	O.D	WALL	DIA	DEPTH
CORNER	DN 50	60.3	3.6	250	750
INTERMEDIATE	DN 40	48.3	2.9	250	600
BRACING STAY	DN 32	42.4	2.6	250	600

DOUBLE ACCESS GATES					
WIDTH OF GATE OPENING	GATE POST			FOOTING	
	DN	O.D	WALL	DIA	DEPTH
6000	DN 80	88.9	4	300	1000



No	DATE	DES	DRN	APP	PROJECT	DESCRIPTION	NUMBER	TITLE
B	22/04/22	ACE	K.J.	A.W.	GG06	ISSUED FOR CONSTRUCTION		
A	23/11/21	ACE	K.Z.	A.W.	GG06	ISSUED FOR REVIEW		
REVISION						DESCRIPTION	NUMBER	TITLE
						REFERENCE DRAWINGS		



DATE: 22/04/22	DES: ACE	DRN: K.J.	APP: A.W.	SCALE: NTS
PROJ No: GG06	DRG No: GG06-10-012			REV: B

GREEN GOLD ENERGY
LOT 2 KERTA ROAD, MYPOLONGA SA 5253
CHAIN WIRE MESH SECURITY FENCE & GATE