

5th November 2021

ADVERTISED PLAN

Rosmy Francis
HARGREAVES DESIGN GROUP
care of
rose@hargreaves.design

Dear Rosmy Francis,

APPLICATION FOR BUILD OVER CONDITIONS

Application ID	521862
Property Address	7 WESTHAM COURT MULGRAVE 3170
Service Location ID	1638800

Thank you for your recent application. Based on the information supplied to Yarra Valley Water the proposed development **may proceed subject to the following conditions.**

Yarra Valley Water has imposed conditions on the erection of structures on or near the water and/or sewer assets and/or easement which you need to review carefully. This consent binds the Owner(s) of the land and successors in title and is enforceable under Section 148 of the Water Act 1989.

Build Over Condition Summary *

Lightweight garages and carports greater than 10 square metres including any pergolas, verandas, gazebos, sails and decking <ul style="list-style-type: none"> • can build over the sewer main and 600mm horizontal and vertical clearance is required
Utility services that are required (Gas, Electricity, Telecommunications) and Property Drains on the property <ul style="list-style-type: none"> • 600mm horizontal clearance is required from any sewer branch and 150mm vertical clearance when traversing the sewer at a 90° angle

* Build Over Condition Summary is to be read in conjunction with the conditions applicable to this application.

The advice in this letter supersedes any previous written or verbal advice that Yarra Valley Water has provided.

If you have any enquiries, please email us at easyaccess@yvw.com.au or for further information visit <http://www.yvw.com.au/help-advice/develop-build>. Alternatively you can contact us on 1300 651 511.

Yours sincerely,

A handwritten signature in black ink that reads "Joe Gargaro". The signature is written in a cursive, flowing style.

Joe Gargaro

Divisional Manager, Development Services

**ADVERTISED
PLAN**

ADVERTISED PLAN

SPECIFIC CONDITIONS APPLICABLE TO THIS APPLICATION:

For any lightweight garages, carports and sheds greater than 10 square metres including any pergolas, verandas, gazebos, sails and decking in the vicinity of a sewer main up to and including 225 mm diameter and less than 3.5 m deep (excluding concrete sewers), the following apply:

1. Refer to attached plan 'A' or 'D' for this structure.
2. The proposed structure can be built over the sewer asset. A minimum 600 mm horizontal clearance from the outside edge of the sewer main is required.
3. Pad footings/foundations are permitted.
4. Driven Piles are not permitted.
5. Where Pad footings are not structurally acceptable, footings/ foundations must extend to a minimum depth to the angle of repose to the invert level of the sewer main, to ensure that no additional load will be placed on the sewer by the structure
6. Any structure over the Yarra Valley Water sewer asset must not exceed 8m in length.

For structures which are required to traverse the sewer main, the foundations crossing the sewer main must maintain a minimum 600 mm vertical clearance, unless demountable.

7. A concrete floor is to be of non-structural infill slab only, as, if required to be removed, it would not affect the integrity of the structure.
8. 24 hour unobstructed access is required.
9. Maximum width allowed for eaves is 600 mm.
10. Height Clearance is required, unless demountable. Height clearance is taken to be height of the walls.
11. A structurally independent roof must be provided when attached to another structure. Engineering plans must be submitted showing the independence of the roof.

For any utility services that are required (gas, electricity, telecommunications) and property drains for a residential property in the vicinity of a property connection branch servicing an adjoining property or multiple lots, the following apply:

1. Refer to attached plan 'K' for this structure.
2. The proposed structure can be built over the property connection branch.

For works adjacent to the property connection branch.

3. Services must maintain a minimum 600 mm horizontal clearance from the edge of the property connection branch.


For works traversing the property connection branch, the following additional conditions apply.

4. Services must maintain a minimum vertical clearance of 150 mm.
5. Services are to traverse the sewer main at a 90 degree angle.
6. No additional load is to be placed on the property connection branch by the services.


**ADVERTISED
PLAN**



GARAGES, CARPORTS AND SHEDS FOR SEWER MAINS LESS THAN 3.5 METRES DEEP AND CONCRETE SEWER MAINS

ONLY APPLICABLE WHERE PAD FOOTINGS ARE STRUCTURALLY PERMITTED



















**ADVERTISED
PLAN**




Yarra Valley Water Sewerage Depth Offset Asset Map	Address 7 WESTHAM COURT MULGRAVE 3170		 Yarra Valley Water ABN 93 066 902 501
	Date 05/11/2021		
	Scale 1:500		



Disclaimer: This Sewerage Depth Offset Plan is for property information only. Yarra Valley Water does not warrant the accuracy or scale of this plan. The company accepts no liability for any loss, damage or injury suffered by any person as a result of an inaccuracy in this plan.

Existing Title		Gas Check Manhole	
Proposed Title		Inspection Shaft	
Sewer Branch		Pipe Junction	
Existing Sewer		Maintenance Shaft	
Circular Manhole		Maintenance Chamber	
Sewer Offset		End of Pipe	
Abandoned Sewer		Rectangular Manhole	
Pump Station		Ventilation	
















Abbreviation Pipe Material	
VC	VITREOUS CLAY
PVC-NP	UPVC - Non Pressure
PVC-PW	UPVC - Profile Wall
CONC	CONCRETE
RC/UON	CC Re/Un-reinforced
PP_SW	POLYPROYLENE
HDPE	POLYETHYLENE
CI	CAST IRON

ASSET DETAILS
Pipe Size: 150 Pipe Material: PVC-NP Average Depth (m): 2.03 Branch Length (m): 1.39
Note: Offsets denoted in brackets $\langle \rangle$ are from the title boundary to centreline of pipe. If pipe offset is not shown, it is unknown and will need to be proven on site. YVW Ref: 1638800




Yarra Valley Water Sewer Branch Asset Map	Address 7 WESTHAM COURT MULGRAVE 3170		 Yarra Valley Water ABN 93 066 902 501
	Date 05/11/2021 Scale 1:500		

Disclaimer: This Sewer Branch Plan is for property information only. Yarra Valley Water does not warrant the accuracy or scale of this plan. The company accepts no liability for any loss, damage or injury suffered by any person as a result of an inaccuracy in this plan.

Existing Title		Access Point Number	GLV2-42
Proposed Title		Circular Manhole	
Sewer Branch		Gas Check Manhole	
Existing Sewer		Inspection Shaft	
Sewer Pipe Flow		Pipe Junction	
Sewer Offset		Maintenance Shaft	
Abandoned Sewer		Maintenance Chamber	
Long Branch Reducer		End of Pipe	

Abbreviation Pipe Material	
VC	VITREOUS CLAY
PVC-NP	UPVC - Non Pressure
PVC-PW	UPVC - Profile Wall
CONC	CONCRETE
RC/UCON	CC Re/Un-reinforced
PP_SW	POLYPROYLENE
HDPE	POLYETHYLENE
CI	CAST IRON

ASSET DETAILS
Branch Size: 100
Branch Material: PVC-NP
Branch Depth (m): 2.49
Branch Length (m): 1.39
Note: Offsets denoted in brackets < > are from the title boundary to centreline of pipe.
YVW Ref: 1638800



Yarra Valley Water

Address 7 WESTHAM COURT MULGRAVE 3170

Build Over Plan Reference: Plan D

Date 05/11/2021

General Structures

Scale 1:500




Disclaimer: This Build Over Plan imposes conditions on the erection of structures on or near Water and / or Sewer assets and / or within easements. This restriction is enforceable under Section 148 of the Water Act 1989.



ABN 93 066 902 501

Yarra Valley Water Application ID: 521862

This plan is to be read in conjunction with the conditions issued by Yarra Valley Water for this application.






LEGEND	SYMBOL	RELEVANT CONDITIONS AND REQUIREMENT
Red circled area		Your property's identification on the plan.
Orange line		Boundary of easement.
Red shaded area		Assets and area that cannot be built over except if conditions are specified.
Yellow hatched area		Assets and area that cannot be built over.
Green highlighted assets		Asset or easement that can be built over subject to conditions specified.



Yarra Valley Water Build Over Plan Reference: Plan K Utilities and Property Drains	Address	7 WESTHAM COURT MULGRAVE 3170			 Yarra Valley Water ABN 93 066 902 501
	Date	05/11/2021			
Disclaimer: This Build Over Plan imposes conditions on the erection of structures on or near Water and / or Sewer assets and / or within easements. This restriction is enforceable under Section 148 of the Water Act 1989.		Scale	1:500		

Yarra Valley Water Application ID: 521862

This plan is to be read in conjunction with the conditions issued by Yarra Valley Water for this application.

LEGEND	SYMBOL	RELEVANT CONDITIONS AND REQUIREMENT
Red circled area		Your property's identification on the plan.
Orange line		Boundary of easement.
Red shaded area		Assets and area that cannot be built over except if conditions are specified.
Yellow hatched area		Assets and area that cannot be built over.
Green highlighted assets		Asset or easement that can be built over subject to conditions specified.

CONDITIONS APPLICABLE TO THIS APPLICATION:

Yarra Valley Water ("YVW") grants its consent to the owner to build a structure or place fill on land over an easement in favour of YVW, over an easement for water supply, sewerage or drainage purposes, or over or within 1 metre of YVW works (referred to as "Owner's Works"), subject to the following terms and conditions:

Standard conditions:

1. A reference in these terms and conditions to YVW includes YVW's employees, agents and contractors.
2. The applicant applying for YVW's consent for the Owner's Works warrant's that they made the application as or on behalf of the owner. A reference in these terms and conditions to the owner includes a reference to the applicant or any successors in title to the owner.
3. YVW's conditional consent is to the owner's application and plans for the Owner's Works as previously provided to YVW. The owner must only construct the Owner Works in accordance with YVW's conditions of consent. Any variation to the owner's application and plans or Owners Works requires a new application to YVW which may be approved or rejected in YVW's absolute discretion.
4. The owner is solely responsible for, and indemnifies and releases and will keep indemnified and released YVW from and against all direct and indirect actions, claims, demands, cost or expenses made, sustained, incurred, brought or prosecuted or in any manner based upon, occasioned by, or attributable to any injury to any person (including illness or death) or loss of or damage to any property which may arise from, or as a result of the Owner's Works, including but not limited to being as a result of the design, construction, placement or presence of the Owner's Works.
5. The owner is solely responsible for, and indemnifies and releases and will keep indemnified and released YVW from and against all direct and indirect actions, claims, demands, cost or expenses made, sustained, incurred, brought or prosecuted or in any manner based upon, occasioned by, or attributable to YVW inspecting, constructing, maintaining, repairing or replacing any assets or other property of YVW beneath or in the vicinity of the Owners Works except to the extent caused by negligence of YVW.
6. YVW makes no warranty or representation and excludes all liability of any kind for the accuracy, adequacy or completeness of any plans or other information it has provided on sewer, water and other assets. The plans and any asset information accompanying this letter are issued solely as a guide for the investigation and identification of the assets specified and must not be used for any other purpose, including to identify any property boundaries, dimensions, structures or other assets. The location of all assets must be proven on site prior to the commencement of any works. Due to ongoing potential asset changes the plans or any other information provided should not be reused at a later date and new plans and asset information should be obtained.
7. The owner must complete and ensure the Owner's Works comply with all applicable laws and authorisations.

**ADVERTISED
PLAN**

8. The owner is solely responsible and warrants the structural integrity and sufficiency of the Owner's Works, including any footings, having regard to the presence of YVW's assets and/or easements.
9. The owner permits YVW to enter into and upon the land and structures contained on the land, for the purpose of inspecting, constructing, maintaining, repairing or replacing assets or other property of YVW, and for that purpose to excavate through any part of the Owner's Works. YVW will not repair or reinstate the Owner's Works.
10. YVW's conditions of consent are binding upon all successors in title to the land. The owner must disclose these conditions to all prospective purchasers, mortgagees or other successors in title.
11. A failure to comply with YVW's conditions of consent will invalidate YVW's consent and render the owner liable for penalties pursuant to the Water Act 1989 which may include fines or imprisonment.
12. Should any monies become due to YVW from the owner pursuant to these terms and conditions, the owner must pay such monies within 30 days of receipt of a written notice from YVW.
13. Our imposition of conditions does not affect the rights of any other parties over the area in question.
14. If there are changes or errors in the details supplied, or we determine that inaccurate information has been provided, this consent may be withdrawn by Yarra Valley Water or additional conditions imposed.
15. Multi-unit and single residential, industrial/commercial developments must meet the requirements stated in WSA 02—3.1 Sewerage Code of Australia, Melbourne Retail Water Agencies Edition - Version 2 - Clause 6.4. This may require a sewer branch connection from an existing maintenance structure or a new maintenance structure.

If a new maintenance structure is required you must apply for conditions at Yarra Valley Water, details are available on the Yarra Valley Water website [easyACCESS Land Development Hub](#).

16. These conditions of consent will be disclosed to any person making an application for an information statement in relation to the land pursuant to section 158 of the Water Act 1989.

**ADVERTISED
PLAN**

RESPONSIBILITY OF SEWER CONNECTION POINTS

ADVERTISED PLAN




Yarra Valley Water's (YVW) responsibility of the sewer connection point is dependent on the location of the sewer main and the first Inspection Opening (I.O), which may be above or below ground. YVW and property owner responsibilities for the sewer connection points are outlined below.

STAND ALONE RESIDENCE

Sewer connection point where the sewer main is **outside** the property.


YVW responsibility ends at the I.O. or up to 1 metre from the property boundary (whichever is less).



STAND ALONE RESIDENCE


Sewer connection point where the sewer main is **inside** the property.

YVW responsibility ends at the I.O. or up to 1 metre from the sewer main (whichever is less).



COMBINED PRIVATE PLUMBING (UNITS, NEIGHBORING PROPERTIES)

YVW responsibility ends at the I.O. or up to 1 metre from the property boundary (whichever is less).



KEY

- Property owner responsibility
- Combined property owner responsibility
- YVW responsibility
- Boundary of property
- Inspection opening (may be below ground or at surface level)
- Building / structure

YVW.COM.AU EMAIL: ENQUIRY@YVW.COM.AU

GENERAL ENQUIRIES: 1300 304 688 EMERGENCIES & FAULTS: 13 2762 LANGUAGE ASSISTANCE: 1300 976 224

Yarra Valley Water, Lucknow Street, Mitcham. Private Bag 1, Mitcham Victoria 3132